



AWPA Test
Centre
Association
Incorporated

**CERTIFICATE
OF TEST**

Client: Masonite (Africa) Ltd

Product: **5.0 mm Underlay**

Type: (AS/NZS1859 Part 2)

The **Underlay** sample supplied by Masonite (Africa) Ltd, identified as 'Sample 4' and received on 13 September 2011 has been tested for Formaldehyde Emission in accordance with AS/NZS 4266:16 Formaldehyde Emission - Desiccator Method

The sample result was **0.07** mg/l which meets the requirements for Class Super E0 as specified in AS/NZS1859 Part 2 i.e. less than 0.3 mg/l.

This test result is for Order No:IM 3721.....

This Certificate relates to the ATCA Report No. 24312, dated 26 September 2011.

Approved Signatory: Vince Wilkinson



NATA Accredited Laboratory Number 1492
NATA endorsed test report. This document shall not be reproduced except in full.



ATCA Laboratory
Postal Address: P.O. Box 216, West Burleigh Qld 4219
Telephone: (07) 5520 4215 Fax: (07) 5520 4216
Address: Unit 3/45 Tallebudgera Creek Road, West Burleigh Qld 4219
Form No:20 Issued 04/06 Rev 01