

VOC Content Test Certificate

Wednesday August 20th, 2008

Supplier: Nexus Adhesives Pty Ltd

42 Healey Road

Dandenong Victoria 3175

Sample Description: MJS Max Bond 2002

Date Tested: August 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design IEQ-13 Green Star Office Interiors IEQ-11	MJS Max Bond 2002
Architectural Sealant 250 grams per Litre	<1 grams per Litre



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0808-14