

VOC Content Test Certificate

Tuesday July 21st, 2009

Manufacturer: Holdfast Adhesives Australia Pty Ltd (90 – 92 Bay Street, Botany NSW 2019)


Sample Description: SureTac PSi carpet tile adhesive

Date Tested: July 2009 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	SureTac PSi
Indoor Carpet Adhesive 50 grams per Litre as VOC content material	<10 grams per Litre as VOC content material
Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	SureTac PSi
Indoor Carpet Adhesive 50 grams per Litre as VOC content material	<10 grams per Litre as VOC content material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0907-12