CETEC
Professional Scientific Solutions

OHS & Environmental Care | Sustainability | Advanced Laboratory/Analytical Services | Technology & Innovation

VOC Content Test Certificate

Thursday 07th November 2019

Supplier: RLA Polymers Pty Ltd (215 Colchester Road, Kilsyth, VIC, 3137, Australia).

Sample Description: AFTEK MS Timber Flooring Adhesive

Date Tested: November 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3690-05 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960 as detailed for paints as well as South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

Specification **Green Building Council of Australia** **Green Star Design & As Built V1.2-13.1.1B** **Green Star Interiors V1.2-12.1.1B**	**AFTEK MS Timber Flooring Adhesive**
General Purpose adhesives and sealants: 50 grams per Litre	**12 grams per Litre as VOC content per material**
We hereby certify that AFTEK MS Timber Flooring Adhesive is below the VOC Content limits of chosen categories specified by Green Star Design, Green Building Council of Australia	

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Tuan Duong
BE (Chem. Eng.)
Consultant

Luke Morley
BSc (Tech)
Consultant

V1911001